



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210

P/O : MPO6402/00375

Project Name :

Project Location :

Lot ID: 2166866

Date Received : Jun 23, 2021

Date Reported : Jul 06, 2021

Report Number : 2019815-1

Page 1 of 1

Sample Number	2166866-1
Sampled Date	Jun 01, 2021 3:03 PM
Sample Description	Sprinkle Drinking Water on June 2021
Date Analysis Commenced	Jun 24, 2021
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.0005	0.001	Not Detected	≤0.3	Based on APHA (2017), 3125	Bangkok
Lead	mg/L	0.00005	0.0002	Not Detected	≤0.01	Based on APHA (2017), 3125	Bangkok
Microbiological Testing							
<i>Clostridium perfringens</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-012 in connection with: - APHA (2017), 9260 A,B - BAM (2001), Chapter 16	Bangkok
<i>Escherichia coli</i>	in 100 mL	-	-	Not Detected	Not Detected	APHA (2017), 9221 F	Bangkok
<i>Salmonella spp.</i>	in 100 mL	-	-	Not Detected	Not Detected	ISO 19250 (2010)	Bangkok
Standard Plate Count	CFU/mL	-	-	<1	≤500	APHA (2017), 9215 B	Bangkok
<i>Staphylococcus aureus</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-054 in connection with: - APHA (2017), 9213 B - BAM (2016), Chapter 12	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Bangkok
Water Testing							
Chloride as Cl	mg/L	0.06	0.2	4.2	≤250	APHA (2017), 4110 B	Bangkok
Nitrate as N	mg/L	0.06	0.2	0.3	≤4	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	6.9	6.5-8.5	APHA (2017), 4500-H(B)	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	34	≤500	Based on APHA (2017), 2540 C	Bangkok
Total Hardness as CaCO3	mg/L	0.5	1	1	≤100	APHA (2017), 2340 C	Bangkok

Guideline : Thai Industrial Standard No. 257-2549 refer to Notification of the Ministry of Industry No. 3470 (B.E. 2549).

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

งานวิเคราะห์น้ำดื่ม
วันที่ 07/07/21

Approved by

Siriluk P.

Siriluk Puengpang
Supervisor

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. Part of the ALS Group

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER