



ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

**Client :** M. Water Co., Ltd.  
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210  
**P/O :** MPO6807/00146  
**Project Name :**  
**Project Location :**

**Lot ID: 2544183**

Date Received : Jul 04, 2025  
Date Reported : Jul 21, 2025  
Report Number : 3364617-1

Page 1 of 4

**Sample Number** 2544183-1  
**Sampled Date** Jul 03, 2025 7:14 PM  
**Sample Description** Sprinkle Drinking Water on July 2025  
**Date Analysis Commenced** Jul 04, 2025  
**Condition of Sample** Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Metals Testing</b>							
Arsenic	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Barium	mg/L	0.0003	0.0005	0.0009	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Cadmium	mg/L	0.0003	0.0005	Not Detected	≤0.003	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Chromium	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Copper	mg/L	0.0003	0.0005	Not Detected	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Iron	mg/L	0.003	0.005	Not Detected	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Lead	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Manganese	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok

PASSED

Wipawan Jantawong  
21/07/25

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.



ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

Client : M. Water Co., Ltd.  
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210

P/O : MPO6807/00146

Project Name :

Project Location :

Lot ID: 2544183

Date Received : Jul 04, 2025

Date Reported : Jul 21, 2025

Report Number : 3364617-1

Page 2 of 4

Sample Number	2544183-1
Sampled Date	Jul 03, 2025 7:14 PM
Sample Description	Sprinkle Drinking Water on July 2025
Date Analysis Commenced	Jul 04, 2025
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Metals Testing</b>							
Mercury	mg/L	0.0001	0.0005	Not Detected	≤0.001	In-house method : STM 05-007 based on United States Environmental Protection Agency, 2002, EPA Method 1631, Revision E	Bangkok
Selenium	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Zinc	mg/L	0.003	0.005	Not Detected	≤3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
<b>Microbiological Testing</b>							
<i>Clostridium perfringens</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-012 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9274 B - FDA BAM online, 2001 (Chapter 16)	Bangkok
<i>Escherichia coli</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 F	Bangkok
<i>Salmonella spp.</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9274 A, B	Bangkok
Standard Plate Count	CFU/mL	-	-	<1	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9215 B	Bangkok

PASSED

Wipawan Jantarong  
21/07/25

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.



ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

**Client** : M. Water Co., Ltd.  
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210

**P/O** : MPO6807/00146

**Project Name** :

**Project Location** :

**Lot ID: 2544183**

Date Received : Jul 04, 2025

Date Reported : Jul 21, 2025

Report Number : 3364617-1

Page 3 of 4

**Sample Number** 2544183-1  
**Sampled Date** Jul 03, 2025 7:14 PM  
**Sample Description** Sprinkle Drinking Water on July 2025  
**Date Analysis Commenced** Jul 04, 2025  
**Condition of Sample** Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Microbiological Testing</b>							
<i>Staphylococcus aureus</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-054 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 B - FDA BAM online, 2016 (Chapter 12)	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Bangkok
<b>Water Testing</b>							
Alkylbenzene Sulfonate as MBAS	mg/L	0.05	0.1	Not Detected	≤0.2	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5540 C	Bangkok
Chloride as Cl	mg/L	0.06	0.2	1.5	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Color	Color unit	-	5	<5	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2120 B	Bangkok
Cyanide as CN	mg/L	0.002	0.005	Not Detected	≤0.07	In-house method : STM 04-007 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - CN (C, E)	Bangkok
Fluoride as F	mg/L	0.05	0.1	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Nitrate as N	mg/L	0.06	0.2	<0.2	≤4	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok

**PASSED**

Wipawan Jantanong  
21/07/25

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.





ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

**Client :** M. Water Co., Ltd.  
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210

**P/O :** MPO6807/00146

**Project Name :**

**Project Location :**

**Lot ID: 2544183**

Date Received : Jul 04, 2025

Date Reported : Jul 21, 2025

Report Number : 3364617-1

Page 4 of 4

**Sample Number** 2544183-1  
**Sampled Date** Jul 03, 2025 7:14 PM  
**Sample Description** Sprinkle Drinking Water on July 2025  
**Date Analysis Commenced** Jul 04, 2025  
**Condition of Sample** Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Water Testing</b>							
Odour		-	-	Odourless	Non Objectionable	In-house method : STM 04-025 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2150 B	Bangkok
pH at 25 degree C		-	-	6.8	6.5-8.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - H (B)	Bangkok
Phenol	mg/L	0.0005	0.001	Not Detected	≤0.001	In-house method : STM 04-022 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5530 D	Bangkok
Sulfate	mg/L	0.15	0.5	0.7	≤200	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	12	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 C	Bangkok
Total Hardness as CaCO <sub>3</sub>	mg/L	0.5	1	<1	≤100	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2340 C	Bangkok
Turbidity	NTU	-	0.1	0.20	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2130 B	Bangkok

**Guideline :** Thai Industrial Standard No. 257-2549 refer to Notification of the Ministry of Industry No. 3470 (B.E. 2549).

**Note :** This Analysis test report is reissued to supersede report No.3350403-1, Date Reported : Jul 16, 2025 due to revise analytical information.

**Remark :**

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

**PASSED**

Wipawan Jantawong  
21/07/25

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

**Client :** M. Water Co., Ltd.  
1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210  
**P/O :** MPO6807/00146  
**Project Name :**  
**Project Location :**

**Lot ID: 2544183**

Date Received : Jul 04, 2025  
Date Reported : Jul 21, 2025  
Report Number : 3364617-2

Page 1 of 1

**Sample Number** 2544183-1  
**Sampled Date** Jul 03, 2025 7:14 PM  
**Sample Description** Sprinkle Drinking Water on July 2025  
**Date Analysis Commenced** Jul 05, 2025  
**Condition of Sample** Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Metals Testing</b>							
Aluminium	mg/L	0.003	0.005	Not Detected	≤0.2	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Silver	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
<b>Water Testing</b>							
Total Solids Dried at 103-105 degree C	mg/L	-	5	14	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 B	Bangkok

**Guideline :** Notification of the Ministry of Public Health No. 61 B.E. 2524 & 135 B.E. 2534 on bottled drinking water (No.2) & 316 B.E. 2553 & Pathogenic 416 B.E. 2563

**Note :** This Analysis test report is reissued to supersede report No.3350403-1, Date Reported : Jul 16, 2025 due to revise analytical information.

**Remark :**

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

PASSED

Wipawan Tan Kanong

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025  
Accreditation No. 1031/47

## Analysis / Test Report

Client : M. Water Co., Ltd.

1 Soi Vibhavadee-Rangsit 41 Yak 1, Sanambin, Donmuang, Bangkok Thailand 10210

P/O : MPO6807/00146

Project Name :

Project Location :

Lot ID: 2544183

Date Received : Jul 04, 2025

Date Reported : Jul 21, 2025

Report Number : 3364617-3

Page 1 of 1

Sample Number	2544183-1					
Sampled Date	Jul 03, 2025 7:14 PM					
Sample Description	Sprinkle Drinking Water on July 2025					
Date Analysis Commenced	Jul 05, 2025					
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)					

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Water Testing</b>						
Bromate	mg/L	0.001	0.005	0.006	In-house method : STM 04-061 based on United States Environmental Protection Agency, 1999, EPA Method 300.1	Bangkok

**Note :** This Analysis test report is reissued to supersede report No.3350403-1, Date Reported : Jul 16, 2025 due to revise analytical information.

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

PASSED  
Wipawan Jantamong  
21/07/25

Approved by

Siriluk P.

Siriluk Bunnak  
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.